

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC26107510035

Valid from: Jun.04,2026

Valid until: Jun.03,2036

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Liaoning MEYGO Electric Automation Equipment Co., Ltd. Room B201, 2nd Floor, MEYGO Industrial Park (formerly Longhai Standard Factory), No. 56-2, Torch Road, Dalian High-tech Park, Liaoning Province.
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Liaoning MEYGO Electric Automation Equipment Co., Ltd. Room B201, 2nd Floor, MEYGO Industrial Park (formerly Longhai Standard Factory), No. 56-2, Torch Road, Dalian High-tech Park, Liaoning Province.
NAME AND LOCATION OF THE FACTORY	Liaoning MEYGO Electric Automation Equipment Co., Ltd. MEYGO Industrial Park (formerly Longhai Standard Factory), No. 56-2, Torch Road, Dalian High-tech Park, Liaoning Province.
PRODUCT NAME, MODEL AND SPECIFICATION	Low-voltage Switchgear Assemblies GGD Main Busbar:InA=1600A~400A(50Hz). (for ratings above 800 A, the rated current at 60 Hz shall be 95% of the rated current at 50 Hz; for ratings of 800 A and below, the rated current at 60 Hz shall be the same as that at 50 Hz);Icw=30kA;Un=380V,Ui=660V;50Hz、60Hz;IP40;Indoor type
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 7251.2-2023
TYPE OF CERTIFICATION SCHEMES	Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑泉

SIGNATURE

刘江



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>